


**LPG VAPORIZER WITH MANIFOLD AND ACCESSORIES
FAISALABAD INSTITUTE OF CARDIOLOGY, FAISALABAD.**

Item Description	Quantity
<p>LPG Vaporizer</p> <p>LPG vaporization Capacity: 150kg/hour or more Unit should comprise at least following hardware/accessories Electric Heating Capacity: 18kw/hour or more Thermostat, connector and breaker should be made of Korea or equivalent Water level relay, separate panel Water level gauge, temperature gauge, pressure gauge Explosion proof design PRV (Rego USA or equivalent) Liquid auto shut-off device Unit should be made of stainless steel material Bidder should be responsible to provide hydrostatic test at minimum 375PSI (G) from OGRA approved/prequalified third party firm. The Unit should be ISO 9001-2015 certified.</p> <p>CYLINDERS MANIFOLD</p> <p>14 x (½ inch ball valve size, 3 feet pipe and shut-off valve), Pipe 6 inch size schedule 40, seamless 2 x (2 inch ball valve size) The bidder should quote PPRC Pipe 2 inch diameter per running feet and supply order will be issued as per actual, further more the lowest bidder will be responsible for complete system installation and any accessories/part/hardware required during installation will also be the responsibility of the bidder. All system should be compatible with all type of OGRA approved LPG Cylinders.</p>	<p align="center">01 No.</p>



Medical Superintendent
 F.I.C, Faisalabad.