

SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF NEW CHILLER, COOLING TOWER, AND AIR HANDLING UNITS FAISALABAD INSTITUTE OF CARDIOLOGY (FIC), FAISALABAD

Part – III

KNOCK DOWN CRITERIA - PRODUCT EVALUATION

(All evaluation parameters defined below are mandatory for compliance.)

Item Sr.No.	SPECIFICATION COMPLIANCE /EVALUATION PARAMETERS OF CHILLER-HEATER			
1	Name of Bidder		M/s Forte Pakistan	M/s National Technologies Inc.
2	Name of Equipment: Chiller-Heater	Brand	York	Hitachi
		Model	YHAU-CGN600EXH	HAU-CGN600EXH
Country of Manufacturer		USA	Japan	
Country of Origin of Product/Model Number		China	China	
Compliance with defined quality standards		Yes	Yes	
Specification Compliance features wise: <ul style="list-style-type: none"> • Sub-Clause 2-02 • Sheet 01 of 05 of Equipment Schedule 		Remarks: Compliant with the sub-clause and equipment schedule parameters. The dual-fuel chiller modelis approved. However, details of the spare parts and other accessories shall be finalized during the technical submittal stage.	Remarks: Compliant with the sub-clause and equipment schedule parameters. The dual-fuel chiller modelis approved. However, details of the spare parts and other accessories shall be finalized during the technical submittal stage.	
Specifications:		Technically Acceptable	Technically Acceptable	
Technical Eligibility of Product:		Eligible	Eligible	
Technical Eligibility of Firm:		Eligible	Eligible	
BID STATUS:		Responsive	Responsive	

Item Sr.No.	SPECIFICATION COMPLIANCE /EVALUATION PARAMETERS OF COOLING TOWER			
1	Name of Bidder		M/s Forte Pakistan	M/s National Technologies Inc.
2	Name of Equipment: Cooling Tower	Brand	Kuken	Kuken
		Model	SKB-870R	SKB-870R
Country of Manufacturer			Japan	Japan
Country of Origin of Product/Model Number			Japan	Japan
Compliance with defined quality standards			Yes	Yes
Specification Compliance features wise: <ul style="list-style-type: none"> • Sub-Clause 2-04 • Sheet 02 of 05 of Equipment Schedule 		Remarks: Compliant with the sub- clause and equipment schedule parameters. The modelis approved. However, details of the spare parts and other accessories shall be finalized during the technical submittal stage.	Remarks: Compliant with the sub- clause and equipment schedule parameters. The modelis approved. However, details of the spare parts and other accessories shall be finalized during the technical submittal stage.	
Specifications:			Technically Acceptable	Technically Acceptable
Technical Eligibility of Product:			Eligible	Eligible
Technical Eligibility of Firm:			Eligible	Eligible
BID STATUS:			Responsive	Responsive

Item Sr.No.	SPECIFICATION COMPLIANCE /EVALUATION PARAMETERS of AIR HANDLING UNITS (AHUs)		
1	Name of Bidder	M/s Forte Pakistan	M/s National Technologies Inc.
2	Name of Equipment: Air Handling Units (AHUs)	Brand	Euroclima
		Model	ZHK Inova
Country of Manufacturer		Italy	Italy
Country of Origin of Product/Model Number		Middle East	Middle East
Compliance with defined quality standards		Yes	Yes
Specification Compliance features wise: <ul style="list-style-type: none"> Sub-Clause 2-05 Sheet 03, 04 & 05 of Equipment Schedule 		Remarks: Compliant with the sub-clause and equipment schedule parameters. The model is approved. However, details of the spare parts and other accessories shall be finalized during the technical submittal stage.	Remarks: Compliant with the sub-clause and equipment schedule parameters. The model is approved. However, details of the spare parts and other accessories shall be finalized during the technical submittal stage.
Specifications:		Technically Acceptable	Technically Acceptable
Technical Eligibility of Product:		Eligible	Eligible
Technical Eligibility of Firm:		Eligible	Eligible
BID STATUS:		Responsive	Responsive

Note:

1. Non compliance of any of above evaluation parts will lead to the rejection of bid straightway.
2. Detail of rejection of any bid will be mentioned in detail.

3. The Technical status of offers will be declared as Responsive, Non Responsive and Substantially Responsive.
4. The offer will be considered as responsive if it fully meets the tender requirement and specifications.
5. The offer which will not be as per requirement of tender and specifications is to be declared as nonresponsive.
6. The bid with minor deviations without any effect on the quality, efficiency, reliability and durability of products will be declared as substantially responsive. The minor deviations will be determined by the Technical Evaluation Committee.
7. The bids declared either as Responsive or Substantial Responsive will be considered as acceptable bid for further processing.
8. Sample, where required by the procuring agency will be evaluated by the Technical Evaluation Committee by analyzing its Production quality, Design, Reliability, Conformance to the specification and safe for the usage etc. This report will become the part of above Performa as sample evaluation report.
9. In case of requirement, Procuring Agency / Technical Evaluation committee may inspect the premises of bidder to inspect the Technical and Managerial Capability/ setups for ensuring proper after sales services.