


**AIR CONDITIONER 4 TON WITH INSTALLATION
FAISALABAD INSTITUTE OF CARDIOLOGY, FAISALABAD.**

Sr. No.	Description	Quantity
1.	<ul style="list-style-type: none">• Unit should be ceiling suspended cassette Type/universal type having capacity 48000 BTUs at Ambient temperature 50° or more.• Compressor should be T3 type technology.• Installation, transportation, lifting, shifting on roof / respective places will be the responsibility of the supplier.• The bidder should quote copper pipe, power cables, control cables per/feet, order will be placed as per actual.• Copper pipe gauge should be 22 SWG or better.• The bidder will be responsible of accessories/ items involved in installation of Air conditioners in FIC premises, no extra cost will be paid.	8 Nos.



Medical Superintendent
Faisalabad Institute of Cardiology,
Faisalabad.

cm *G*